




For: Hardware Shop, Co. Westmeath



Energy performance of your business

	Current	Potential
Energy management	★★	★★★★★
Building fabric	★	★★★★★
Building services	★★	★★★★★
Manufacturing & processing equipment	★★★	★★★★
Manufacturing & processing controls	★★	★★★★
Use of renewables	★★★★	★★★★★



Recommended actions that will help reduce your organisation's emissions by 94% and annual energy spend by €6,846.

Action	Energy saving per yr (€)	Emissions reduction per yr (t CO ₂ e)	Cost of action (€)	Payback period (years)	First step
Boiler Controls Upgrade	€ 450	1.5	€ 1,000	2.2	Contact boiler company
Monitoring and control of Energy Use and staff awareness programme for all users.	€ 737	1.49	€ 500	.7	Contact supplier and contact obligated party to assist with CEG application
Lighting	€ 197	0.2	€ 300	1.5	No Grant:
Lighting Controls	€ 1,233	1.1	€ 300	.02	No Grant: Contact Electrical Contractor – OWL Monitoring System
Building fabric upgrades, doors and windows	€ 684	1.5	€ 18,500	18.9	Contact supplier and contact obligated party to assist with CEG application
Pipework insulation	€ 384	1.2	€ 1,000	1.8	Contact supplier and contact obligated party to assist with CEG application
Car Charger	€		€ 1,600	3	Contact supplier and contact obligated party to assist with CEG application
More efficient use of Air Compressor	€ 272	1.2	€ 0	Instant	Explained in the report: repairs made by own staff
Install PV	€ 1,036	1	€ 8,000	5.4	Contact supplier and contact obligated party to assist with CEG application
Install Battery	€ 1,924	2	€ 5,000	1.3	Contact supplier and contact obligated party to assist with CEG application
Total	€ 6,917	11	€ 36,200	5.2	